

F-2-32
SPE-0010
SPE-4-8
SPE-10-10
A-702

RECORDED
MARCH 17 1964
T & C PA 16.

Ottawa, March 17th, 1964.

Ferranti-Buchard Electric Limited,
St. Catharines, Ontario.

Attention: Mr. F. L. Mills,
Supervisor of Engineering,
Instrument Transformers

Dear Sir:

This is to advise that Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to four Type "M15" 2000-S ampere, 10000 volt, Oilless Compound Filled Current Transformers, Serial numbers 2-61007, 2-61008, 2-61009 and 2-61010. Metering accuracy is 0.500.1, 50.9, B(250.9), B2.0. Nameplates are stamped 0.500.9.

These transformers are for the Hydro Electric Power Commission of Ontario for installation at Ottawa - Riverdale T.S.

Yours truly,

W. J. J. Fraser

for H. F. Sawyer
Chief, Electricity & Gas Division
Standards Branch

JTS/ST

c.c. Mr. W. F. Miller, District Inspector (RIG) Ottawa, Ontario.

c.c. Hydro-Electric Power Commission of Ontario through Mr. Miller