

RECORDS

SPE-0013

APR 7 1964

T & C PA 16

SE-85-4-5

OTTAWA, April 2, 1964.

Farranti-Packard Electric Limited,
St. Catharines,
Ontario.

Attention: Mr. E. L. Mills,
Supervisor of Engineering
Instrument Transformers

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to one only Type "4035", 400/800-5 amperes, 27000-115 volt, 60 cycle, 3-phase, 3-wire, Outdoor Oil Insulated Metering Equipment, Serial number 2-05070.

This Metering Outfit is for the Saguenay Power Company Limited at Isle Malin, P.Q. and contains: 2 Type "4035", 27000-115 volt Voltage Transformers, Serial numbers 2-05041 and 2-05042 with Metering accuracies of 0.3, 0.5, and 2 Type "4035", 400/800-5 amperes Current Transformers, Serial numbers 2-05073 and 2-05079 with Metering accuracies of 0.3, 0.5, 0.9, 3(2 x 0.9) on either ratio.

Yours very truly,

W. J. J. Fraser

(for) E. P. Power,
Chief,
Electricity & Gas Division,
Standards Branch.

JHG/BI

cc- Mr. J.R. Trudel, Quebec.

cc- Saguenay Power Co. (Through Mr. Trudel)

SL-100-516-74

→ 370-13