

SE-85-4-5
 SL-100-50
 SPE-15

Ottawa, April 14, 1964.

Ferranti-Packard Electric Limited,
 St. Catharines,
 Ontario.

Attention: Mr. F.L. Mills,
 Supervisor of Engineering,
Instrument Transformers.

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to two only Type "EA" Auxiliary Current Transformers with serial numbers 2-67034 and 2-65936.

These transformers are to be used for totalizing the secondary currents from three sets of main current transformers in the ratios of 6.67 + 6.67 + 5 to 5 amperes. Accuracies are given as 0.3B0.1, B0.5, B0.9; 0.6B (2 x 0.9) and the nameplates are marked "0.3B0.5".

These units are for the B.C. Hydro and Power Authority for use at Duncan Bay 13 Kv Transformer Station.

Yours truly,



(for) D.F. Power, Chief,
 Electricity and Gas Division,
 Standards Branch.

JRG/cf

c.c.-- Mr. R.G.D. Ward, D.I. of E&G, Vancouver
 B.C. Hydro & Power Authority through Mr. Ward.