

3PE-0019

SE-35-4-6

OTTAWA, August 21, 1964.

Ferranti-Packard Electric Limited,
St. Catharines, Ontario.

Attention: Mr. E. L. Mills,
Supervisor of Engineering,
Instrument Transformers.

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to one only Type "C715", 400/500-5 amp., 21,00/4160Y-120 Volt, 60 Cycle, 3 Phase, 4 wire, Outdoor Oil-Insulated Metering Equipment - Serial number 2-67503.

This outfit is for the Southern Canada Power Company Limited for installation at St-Hyacinthe, Quebec and contains 2 - Type "C715" 21,00/4160Y-120 volt voltage transformers approved under S.A. 506 (unrated), and 3 Type "C715" 400/500-5 amp current transformers serial numbers 2-67503, 2-67501 and 2-67502. The metering accuracies of these transformers is 0.30.1, 0.9; 0.60(2 x 0.9) on the 400-5 ratio and 0.30.1, 0.9, 0.9(2 x 0.9) on the 500-5 ratio and the nameplate is marked 0.30.9.

Yours very truly,

ORIGINAL SIGNED BY
E. E. ANDERSON

Acting Chief,
Electricity and Gas Division,
Standards Branch.

cc- Mr. Haysmith, Montreal.
cc- Southern Canada Power Co.
(through Haysmith)

5094

cc- SE-35-4-5
cc- SE-100-318723
cc- 3PE-28.19

5093

5092