

NOV 25 1964

140 R.A. 10.

SL-35-4-6
SL-35-4-5
SL-100-596 V4Y
→ SL-100-24

Ottawa, August 24, 1964.

Ferranti-Packard Electric Limited,
St. Catharines,
Ontario.

Attention: Mr. E.L. Hills,
Supervisor of Engineering,
Instrument Transformers.

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to one only Type "1135", 400/300-5 amp. 27600-115 volt, 60 cycle, 3 phase, 3-wire outdoor oil insulated metering equipment, serial number 2-63170.

The outfit contains:-

2 Type "1135" 27600-115 volt voltage transformers serial numbers 2-63172 and 2-63173, and

2 Type "1135" 400/300-5 amp. current transformers serial numbers 2-63174 and 2-63175.

Metering accuracy of the voltage transformers is 0.3% at 0.6cos with a nameplate marking of 0.3%, and for the current transformers 0.300.1, 0.30.2, B (2 x 0.3) with a nameplate marking of 0.300.2.

This metering equipment is for the Hydro Electric Power Commission of Ontario for installation at Glenview S.S., Ancaster, Ontario.

Yours very truly,

ORIGINAL SIGNED BY
G. E. ANDERSON

Acting Chief,
Electricity and Gas Division,
Standards Branch.

SL/af

- c.c.--1) Mr. W.A. McEwen, Dist. Insp. of ESE, Toronto
- 2) Hydro Electric Power Co. of Ont. (through Mr. McEwen)

511
5113