

SPE-0026

SL-100-26

1-2-1964

Enclosed  
EX-200-261

Fax 100, August 20th, 1964

SL-100-SPE-26

Permittee-owned Electric Motors,  
St. Catharines, Ontario.

Attention: Mr. R. L. MILLS  
Manager of Engineering  
Engineering Department

Dear Sirs:

This is to advise that special Normal has been granted by the Standards Bureau, CECB in Canada for 115kV transformer, to the only type 115kV 115MVA 12.47%/12.5%/12.5% TURNS, 60 Hz, outdoor, oil-immersed voltage transformer.

These transformers are for the British Columbia Hydro & Power Authority of Vancouver, two 115MVA units 115kV and 22kV and are for use in Vancouver and three 115MVA units 115kV, 22kV and 33kV are for use in Kamloops, B.C.

The metering accuracy of all units is 0.5% and this is the accuracy shown on the nameplate.

Yours truly,

ORIGINAL SIGNED BY  
G. E. ANDREW

G. E. ANDREW,  
ASST. CHIEF ELECTRICITY & GEN.,  
Standards Bureau.

EX-200

C.C. MR. R. G. D. WARD, Dist. Engg. (115) Vancouver, B.C.  
C.C. British Columbia Hydro & Power Authority through Mr. Ward.