

SI-100-2700  
SI-2-11  
SI-100-SPC-27

September 23rd, 1964

Catmon Power Company Limited,  
65 Adelaide Street,  
Ottawa, O. C.

Attention: Mr. J. Crosby

Dear Sir:

This is to advise that Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to one modified Standard Type SP-3 Metering Unit, serial number 12777, containing two voltage transformers of 2300-115 ratio and three current transformers of 300/100-5 ratio.

The modification consists of re-connecting the voltage transformers, formerly 1500-115 ratio, for 2300-115 ratio. Accuracy ratings of the voltage transformers are 0.3%; 0.5%; 1.2%. The current transformers have accuracy ratings of 0.5%, 1.0%, 2.0% on both ratios. The serial numbers of the voltage transformers are 127775 and 127776. The serial numbers of the current transformers are 127772, 127773 and 127774.

This metering unit is owned by Catmon Power Company, Ottawa, Que.

Sours truly,

*W. J. S. Fraser*

(Sgt) W. J. S. Fraser  
Senior Chief Inspector & C.S.  
Standards Branch

WJSP/cn

c.c. Mr. J. P. Miller, District Inspector of M.E., Ottawa

5784

RECORDS

SEP 23 1964

5785