SPE-0029

Ottawa, October 27th, 1964

RECORDS

NOV 2 1964

I & C PA 16

Canadian General Electric Limited,
Peterborough, Ontario.

Attention: Mr. F. L. Mills
Department of Engineering
Instrument Transformers

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch Canada to obtain for Military purposes to one only type "VTOT" 69 kV, 60 cycle 3 phase, 3 wire, outdoor oil-insulated metering equipment, serial number S-70720.

The equip contains 3 type "VTOT" 69000-115 volt voltage transformers serial numbers S-70719 and S-70720 and 3 type "CTOT" current transformers, the latter are approved under S-A.427. The metering accuracy of the voltage transformers is 0.3%.

This equipment is for the Naval Dockyard Limited, Shelburne Bill at Fort Arthur, Ontario.

Yours very truly,

C. A. Adams
Chief Engineer
Standards Branch

CA/ce

c.c. Mr. C. A. Hinman, Mgr. Engg. (PTC) Sydney, N.S.
Naval Dockyard Limited, Fort Arthur (Shelburne) Ont.

6700

6798