

RECORDS  
DEC 16 1964  
I & C PA

RECORDS  
NOV 17 1964  
I & C PA 15

SPI-0036

RECEIVED  
NOV 17 1964  
I & C PA 15

Ottawa, November 12th, 1964

Foranville-Canada Minerals Limited,  
St. Catharines, Ontario.

Attention: Mr. M. E. Mills  
Department of Geology  
Department of Mineral Resources

*WJL*

Dear Sirs:

This is to advise that special approval has been granted by the standards committee for the use in Canada of electrical equipment of the only type of 220V 60Hz 2-wire 2-wire, 2700-215 model, 0.31 amp, 3 phase, 3 wire, 3-wire 220V 60Hz 2-wire electrical equipment serial number 2-71007.

The order contains 2 type "215" 2700-215 model voltage transformers serial numbers 2-71008 & 2-71009, and 2 type "215" 300/300-5 amp current transformers serial numbers 2-71010 & 2-71011.

The percentage accuracy of the voltage transformers is 0.31 and the current transformers is 0.5 S.O.

This equipment is for the Agency Power Company Limited, Koro-Keligo, Quebec.

Yours truly,

C. J. [Signature]  
[Title]  
[Address]

c.c. Mr. J. N. [Name], 1118, [Address], [City], [Province], [Country].  
Agency Power Company Limited (through Mr. [Name])

7000