

JAN 1965

SPF-0040

T&CPA 16.

40

CE-15-15  
SI-10-15  
SI-10-15

January 11th, 1965

Hydro Electric Limited,  
191 Queen Street,  
Winnipeg 17,  
Manitoba.

Attention: Mr. Donald G. Scott  
Engineering Department

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes to two only type "A-1" 2500-120 volts 60 cycles 5KV class oil insulated outdoor Voltage Transformers serial numbers 11377 and 11378.

These transformers are two bushing type and the accuracy class marked on the nameplate is C.S.T.Y. 0.51.

These units are for use by the Manitoba Hydro at Cretna, Manitoba.

Yours truly,

G. G. Scott  
Chief, Electricity & Gas Division,  
Standards Branch.

GG/cn

c.c. - Mr. D. G. Scott, P. E. of Electricity & Gas, Winnipeg

c.c. - Manitoba Hydro, Winnipeg (through Mr. Scott)

2233

2240

2241