

RECORDS

JAN 6 1965

T & C PA 16.

SPF-0045

(45)

2-75-1-5

2-75-1-6

2L-100-7537

2L-100-7545

Ottawa, January 6, 1965.

Ferranti-Packard Electric Limited,  
31. ...  
Ontario.

Attention: Mr. S. L. Mills,  
Supervisor of Engineering,  
Instrument Transformers.

Re: Special Approval - One Only Type "215" Metering  
Outfit, Serial Number 2-75537

Dear Sirs:

This is to advise that Special Approval has been granted  
by the Standards Branch for use in Canada for billing purposes to  
one only type "215" 400/100-5 amp., 2500/13800V-115 volt, 60 cycle,  
Outdoor Compound-filled Metering Outfit, Serial Number 2-75537.  
This outfit contains:

- 2 - type "2015" Voltage Transformers, approved under  
Circular 2-71.535; and
- 3 - type "2015" 400/100-5 amp. Current Transformers,  
Serial Numbers 2-75532, 2-75533 and 2-75534.

The metering accuracy of the current transformers is  
0.350.1, 0.5, 0.5, 0.25.0 and the nameplate is marked "0.350.0".

This outfit is for the Dominion Textile Company Limited  
at ...

Yours very truly,

E. Ryan,  
Chief, Electricity and Gas Division,  
Standards Branch.

c.c. to Mr. J. F. ...  
c.c. to Dominion ...

to the meter of Electricity and Gas, Montreal  
dated (to Mr. Ryan)