

TSPF-0046
46

RECEIVED

JAN 20 1965

BR 68A 16.

SR-55-1-6,
SI-193-5172,
SI-202-1746

Ottawa, January 13, 1965.

Ferranti-Packard Electric Limited,
ST. CATHARINES,
Ontario.

Attention: Mr. E. L. Mills,
Supervisor of Engineering,
Equipment Department.

Re: Special Approval - One Only Ferranti-Packard Type "VU15"
Voltage Transformer, Serial Number 2-75590

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in service for testing purposes to one only Ferranti-Packard type "VU15" 750/12000-110 volt, 60-cycle Outdoor Compound-filled Voltage transformer, Serial Number 2-75590.

The ratio of this transformer is 60:1:1, the same as that of two type "VU" voltage transformers, serial numbers 20304 and 20305, which were granted special approval by letter of June 13, 1964. However the accuracy class stamped on the nameplate of the present transformer is "0.2%".

This transformer is for Hydro-Quebec, for installation at LaLarre, Abitibi Ouest.

Yours very truly,

H. GIBBS,
Chief, Electricity and Gas Division,
Standards Branch.

RG/seo

c.c. to Mr. G. E. Milne, District Inspector of E&G, Sudbury
c.c. to Hydro-Quebec (Attention: G. E. Milne)