

SPE-0048

48

SE-05-1-5

SI-100-701A

~~SI-100-1001~~

Ottawa, January 27, 1935.

Canadian General Electric Company Limited,  
Industrial Products Department,  
215 King Street West,  
Toronto,  
Ontario.

Attention: Mr. J. G. McMillan,  
Sales Manager,  
Sales Department.

Re: GENERAL ELECTRIC - Ten Only - General Electric  
Type "A-12" Current Transformers, Serial  
Numbers 5511 and 5512

Dear Sirs:

This is to advise that Serial Agreement has been granted  
by the Industrial Products Department for fitting your Ten  
only Type "A-12" 100/5 A.C. 60-cycle Current Trans-  
formers, Serial Numbers 5511 and 5512.

The accuracy of these current transformers is as stated in  
Circular 4-11-31, with the addition of 2.5% (2.5). The regulations  
are marked "A-12". The current transformer is based on the  
20:5 ratio and has over 50 turns secondary winding. The accuracy  
with 7.5% error secondary current is 2.5% (2.5).

These units are for the Industrial Products Department of  
Ontario for use at the Ottawa office. Serial Numbers 5511 and  
5512. Do not include, Ontario.

Yours very truly,

K. J. Ryan,  
Chief, Industrial and Sales Division,  
General Electric.

RC/acs

c.c. to Mr. J. G. McMillan, Industrial Products Department, Ottawa  
c.c. to The Hydro-Electric Commission, Ottawa, Ontario (Mr. McMillan)