

(49)

1-10-1935
1-10-1935
1-10-1935

Ottawa, January 10, 1935.

Ferranti-Buchard Electric Limited,
St. Catharines,
Ontario.

Attention: Mr. E. L. Mills,
Supervisor of Engineering,
Instrument Transformers.

Re: Special Approval - Two sets of voltage transformers "K1000"
Manufactured by Ferranti-Buchard Electric Co. Ltd.

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for Ferranti-Buchard type "K1000" 10/0.5 amp., 22000-115 volt, 60 cycle, 2-wire out-door, oil-insulated metering equipment, serial numbers 2-74125. This outfit contains:

- 2 - type "K1000" 22000-115 volt V.I.T. transformers, serial numbers 2-74121 and 2-74122; and two "K1000" current transformers approved under Circular 1-10-35.

The metering accuracy of the voltage transformers is 0.5% at 20, and the ammeteres are marked 0.5%.

This equipment is for the Federal Public Electric of Canada Limited for installation at 1201 Bank Street, Ottawa, c/o The Federal Building, 1201 Bank Street, Ottawa, Ontario.

Yours very truly,

H. J. ...
Chief, Electricity and Gas Division,
Standards Branch.

HC/ace

c.c. to Mr. J. ...
c.c. to Federal Public Electric of Canada Limited (through Mr. ...)