

SPÉ-0050

50

1-125-1-6
1-125-5-1-1-6
1-125-4-1-1-6

Ottawa, January 16, 1955.

Forrester-Packard Electric Limited,
St. Catharines,
Ontario.

Attention: Mr. P. L. Mills,
Supervisor of Engineering,
Instrument Installation.

Re: Special Approval - See 25/50-5 amp., 27500-115 volt. oil-cooled, 3-pole, 3-wire out-
door oil-insulated Metering Equipment, Serial Number 2-75542

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only type "25/50-5 amp., 27500-115 volt. oil-cooled, 3-pole, 3-wire outdoor oil-insulated Metering Equipment, Serial Number 2-75542. This outfit contains:

- 2 - type "25/50-5 amp., 27500-115 volt. oil-cooled, 3-pole, 3-wire outdoor oil-insulated Metering Equipment, Serial Numbers 2-75546 and 2-75547; and type "25/50-5 amp., 27500-115 volt. oil-cooled, 3-pole, 3-wire outdoor oil-insulated Metering Equipment, Serial Numbers 2-75548 and 2-75549.

The metering accuracy of the voltage transformers is 0.3% and 0.6%, and the nameplates are marked "0.3% and 0.6%".

This equipment is for the Hydro-Electric Power Commission of Ontario for installation at Windsor, Ontario.

Yours very truly,

H. G. G. G.,
Chief, Electrical and Gas Division,
Standards Branch.

HG/soo

- c.c. to Mr. J. Fleming, District Inspector of E.P.C., Windsor, Ontario
- c.c. to the Hydro-Electric Power Com. of Ontario (London, Mr. Fleming)