

10-35-4-3  
SI-100-5177  
SI-100-07852

(52)

Quebec, January 29, 1965.

Ferranti-Packard Electric Limited,  
ST. CHARLES,  
Ontario.

Attention: Mr. E. L. Mills,  
Supervisor of Engineering,  
Manufacturing Division

Re: Special Approval - Four 1000/25000-10 Volt  
Transformers, Serial Numbers 2-75013  
2-75014

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to two only type "2500" 1000/25000-10 volt, 5000 VA, outdoor oil-insulated Voltage Transformers, Serial Numbers 2-75013 and 2-75014. The metering accuracy of these transformers is "0.1% 200/300", and this is marked on the nameplate.

These transformers are for the Saguenay Electric Company at Chateaufort, Quebec.

Yours very truly,

F. J. Ryan,  
Chief, Electricity and Gas Division,  
Standards Branch.

RC/ace

c.c. to Mr. J. H. Brudal, District Engineer at Chateaufort, Quebec  
c.c. to Saguenay Electric Company (Serial Nos. 2-75013)