

86-100 107

RECEIVED
JAN 26 1965
SPE-0053

(53)

Ottawa, January 26, 1965.

Forronti-Pachani Electric Limited,
St. Catharines,
Ontario.

Attention: Mr. E. L. Mills,
Superintendent, Engineering,
Forronti-Pachani Electric Limited.

Re: Special Approval - Two only Forronti-Pachani Type "1835"
Voltage Transformers, Serial Numbers
2-7540 and 2-7541.

Dear Sirs:

This is to advise that special approval has been granted by the Standards Branch for use of two only of the type "1835" voltage transformers, 2-phase, 2-wire system (30-115 volt), 3-wire, 3-phase, 2-wire system (30-115 volt) and 3-wire, 3-phase, serial numbers 2-7540 and 2-7541.

Serial Number 2-7540 contains:

2 - type "1835" Voltage Transformers, Serial Numbers
2-7540 and 2-7541.

Serial Number 2-7541 contains:

2 - type "1835" Voltage Transformers, Serial Numbers
2-7542 and 2-7543.

These voltage transformers have a winding capacity of 2.0 VA; 1.0 VA and the associated core area of 11.0 sq. in.

The above transformers used in each of the units are type "1835", approved under Standard S-1835.

This approval is for the use of electric power distribution of Ontario for industrial use at the Forronti-Pachani Electric Limited.

Very truly,
Yours,

H. J. ...
Director, Standards Branch, Division,
Ontario.

Notes

c.c. to Mr. J. ...
c.c. to Mr. ...