

SPE-0054

RECEIVED
SEP 10 1965
BY TELETYPE

SL-100-5745
SL-100-5746
SL-100-5745I
SL-100-5745

Ottawa, May 7, 1965.

Ferranti-Packard Electric Limited,
ST. CATHARINES,
Ontario.

Attention: Mr. F. L. Mills,
Supervisor of Engineering,
Instrument Department.

Re: Special Approval - one only Ferranti-Packard type "7245"
current transformers, serial number 2-71605

Dear Sirs:

This is to advise that Special Approval has been granted by
the Standards Council for use in Canada of the following equipment to one only
type "7245" 25/50-5 r.p.s., 4000-125 Volt, 3-phase, 3-wire, 3-wire
Outdoor oil-immersed metering equipment, Serial number 2-71605.
This outfit contains:-

- 2 - type "7245" current transformers, as per invoice 2-71607; and
- 2 - type "7245" Voltage transformers, serial numbers 2-71601 and 2-71602.

The voltage transformers have a metering accuracy of 0.3% at 0.8Z
and the ratios are correct to 0.1%.

This equipment is for the Hydro-Electric Power Commission of
Ontario for installation at Ottawa, Ontario.

Yours very truly,

T. E. Ryan,
Chief, Electricity and Gas Division,
Ontario Hydro.

TEY/aco

c.c. to: Mr. F. L. Mills, District Engineer of Hydro-Electric Power, Ottawa
c.c. to: Mr. E. J. Ryan, District Engineer of Hydro-Electric Power, Ottawa (Mr. Miller)