


## RECORDS

SPE 0055

SEP 10 1965

I &amp; G P.D.



Ottawa, May 7, 1965.

Ferranti-Lackard Electric Limited,  
St. Catharines,  
Ontario.

Attention: Mr. E. L. Mills,  
Supervisor of Engineering,  
Hydro-Quebec Department

No: Special Approval - Two Only Ferranti-Lackard Type "K25"  
Voltage Transformers, Serial Numbers 2-71124 and 2-71125

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for Billing purposes to the only type "K25" 25/500 amp., 200/0-120 volt, 60-cycle, 3-phase, 3-wire Outdoor Oil-Insulated Metering Equipment, Serial Numbers 2-71124 and 2-71125.

Outfit Serial Number 2-71124 contains:-

2 - Type "K25" Voltage Transformers, Serial Numbers  
2-71126 and 2-71127.

Outfit Serial Number 2-71125 contains:-

2 - type "K25" Voltage Transformers, Serial Numbers  
2-71128 and 2-71129.

These voltage transformers have a metering accuracy of 0.5% D.L with the uncalibrated mark "0.3%".

The Current Transformers used in each of these outfit are type "K45", approved under Circular S-1-117.

This equipment is for Hydro-Quebec, Montreal, P.Q. for shipment to stores in Montreal.

Yours very truly,

J. M. J.  
L. G. D.

K. Dryer,  
Chief, Electricity and Gas Division,  
Standards Branch.

J. M. J.  
L. G. D.

R.M./cc

c.c. to: Mr. J. F. Macmillan, District Inspector of Elec. & Gas, Montreal  
c.c. to: Hydro-Quebec, Montreal (Through Mr. Dryer)