

SPE-0056

for P

RECORDS

SEP 10 1965

T & C PA

SL-25-4-5

SL-15-4-6

SL-100-50675K

SL-100-50753

Ottawa, May 7, 1965.

Ferranti-Packard Electric Limited,
ST. CATHARINES,
Ontario.

Attention: Mr. E. L. Mills,
Supervisor of Engineering,
Instrument Transformers.

Re: Special Approval - One Only Ferranti-Packard Type "K135"
Metering Equipment, Serial 2-70725

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for Billing purposes to one only type "K135" 400/200-5 amp., 2700-215 volt, 60-cycle, 3-phase, 3-wire Outdoor Oil-Insulated Metering Equipment, Serial Number 2-70725.
This outfit contains:-

- 2 - type "K135" Voltage Transformers, Serial Numbers 2-70716 and 2-70717; and
- 2 - type "K135" Current Transformers, Serial Numbers 2-70723 and 2-70724.

The voltage transformers have a metering accuracy of 0.3% with the nameplates marked "0.3%" and the current transformers have a metering accuracy of 0.5% 0.1, 0.2, 0.5 (Max.) with the nameplates marked "0.5 0.0".

This equipment is for The Hydro-Electric Commission of the Township of Toronto for installation at Innisville, Ontario.

Yours very truly,

H. Grier,
Chief, Electricity and Gas Division,
Toronto, Ontario.

47413

47413

47413

EAN/mec

c.c. to: Mr. V. R. Wilson, District Inspector of Gas, Toronto
c.c. to: The Hydro-Electric Commission of the Township of Toronto
(Through Mr. G. Grier)