

SEP 10 1965

SPE-0057

WALTON

2-2-5  
2-2-6  
SI-17-5331-1  
1-11-57

Ottawa, May 7, 1965.

Ferranti-Packard Electric Limited,  
ST. CATHARINES,  
Ontario.

Attention: Mr. E. L. Mills,  
Supervisor of Engineering,  
Instrument Department.

Re: Special Approval - One Only Ferranti-Packard Type "M35"  
Winding Transformer, Serial No. 2-20471

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only type "M35" 75/150-5 amp., 250 - 115 volt. 0.2 class, 2-phase, 3-wire outdoor oil-insulated metering equipment, Serial Number 2-20471. This outfit contains:-

2 - type "M35" Voltage Transformers, Serial Numbers 2-20457 and 2-20461, having a metering accuracy of 0.2% with the nameplates marked "0.2%".

The Current Transformers used in this outfit are type "M35", approved under Circular S-71.427.

This equipment is for the Burlington Public Utilities Commission for installation at the Steele Research Centre, Burlington, Ontario.

Yours very truly,

E. Taylor,  
Chief, Electricity and Gas Division,  
Standards Branch.

2733

2733

EM/mco

2710

c.c. to: Mr. C. D. Irving, District Inspector of Electricity, Gen. Hamilton  
c.c. to: Burlington Public Utilities Commission (through Mr. Irving)