

0-0
SPE-0058

SE-85-1-5
SE-85-1-6
SL-100-526V51
SL-100-526V51

Ottawa, May 7, 1965.

Ferranti-Blackburn Electric Limited,
ST. CATHARINES,
Ontario.

Attention: Mr. W. J. Mills,
Superintendent of Engineering,
Industrial Division.

Re: Special Approval - One Only Ferranti-Blackburn Type "K35"
Measuring Equipment, Serial No. 2-77722

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only type "K35" 100/200-5 amp., 27000-115 volt, 60-cycle, 3-phase, 3-wire busbar fully-insulated Measuring Equipment, Serial Number 2-77722. This outfit contains:-

- 2 - type "K35" Voltage Transformers, Serial Numbers 2-77717 and 2-77718, having a metering accuracy of 0.3% with the nameplates marked "0.3%".

The current transformers used in this outfit are type "K35" approved under S-1.427.

This equipment is for the Hydro-Electric Commission of the Township of North York for installation at Toronto, Ontario.

Yours very truly,

4735

4735

EAM/lcc

H. Oyer,
Chief, Electricity and Gas Division,
Standards Branch.

c.c. to: Mr. W. J. Nelson, District Inspector of Gas, Toronto.
c.c. to: The Hydro-Electric Commission of the Township of North York
(through Mr. Nelson)