

SE-55-4-5  
 SE-35-4-6  
 SL-100-SIB  
 SL-100-30 A

Ottawa, Jan 6, 1965.

Ferranti-Packard Electric Limited,  
 87, CATHARINES,  
 Ontario.

Attention: Mr. F. L. Mills,  
 Supervisor of Transformers,  
 Instrument Transformers.

Re: SPECIAL APPROVAL - One Only Ferranti-Packard Type "E4-5"  
 Outdoor Compound-Filled Metering Outfit,  
 Serial Number 2-82532

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only type "E4-5" 500/1000-5 amp., 24000/41600-120 volt, 60 cycle, 3 phase - 4 wire Outdoor Compound-Filled Metering Outfit, Serial Number 2-82532. This outfit contains:

- 2 - type "DC5" Voltage Transformers, approved under Circular E-EA.506 (amended); and
- 3 - type "EC5" 500/1000-5 amp. Current Transformers, having a nameplate accuracy of 0.1% on both ratios.

This equipment is for the Southern Canada Power Company Ltd. at St-Roch, Quebec.

Yours very truly,

K. Geyer, Chief,  
 Electricity and Gas Division,  
 Standards Branch.

RAW/mec

c.c. to: Mr. J. F. Heynath, District Inspector of Electricity and Gas, Montreal  
 c.c. to: Southern Canada Power Company Ltd. (through Mr. Heynath)