

SPE-0061

SL-85-4-5  
SE-85-4-6  
SL-100-376  
SL-100-576 V41

Ottawa, July 6, 1965.

Ferranti-Packard Electric Limited,  
ST. CATHARINES,  
Ontario.

Attention: Mr. E. L. Mills,  
Supervisor of Engineering,  
Instrument Transformers.

Re: SPECIAL APPROVAL - One Only Ferranti-Packard Type "ME69"  
Outdoor Oil-Insulated Metering Equipment,  
Serial Number 2-82221

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only type "ME69" 200/100-5 amp., 69000-115 volt, 60-cycle, 3 phase - 3 wire Outdoor Oil-Insulated Metering Equipment, Serial Number 8-2221. This equipment contains:

- 2 - type "ME69" 69000-115 volt Voltage Transformers, Serial Numbers 2-82212 and 2-82213; and
- 2 - type "ME69" 200/100-5 amp. Current Transformers, Serial Numbers 2-82219 and 2-82220.

The accuracy classes marked on the nameplates are "0.35%" for the voltage transformers, and "0.350%" for the current transformers.

This equipment is for The New Brunswick Electric Power Commission at Edmundston, New Brunswick.

Yours very truly,

*K. Cryer*  
R. Cryer, Chief,  
Electricity and Gas Division,  
Standards Branch.

EAN/mee

C.C. to: Mr. R. H. Beattie, District Inspector of Elec. & Gas, Saint John  
C.C. to: The New Brunswick Electric Power Commission (through Mr. Beattie)