

SE-35-4-5  
 SE-35-4-6  
 SI-100-SPE  
 SI-100-596 V<sub>50</sub>

Ottawa, July 6, 1965.

Ferranti-Packard Electric Limited,  
 ST. CATHARINES,  
 Ontario.

Attention: Mr. E. L. Mills,  
 Supervisor of Engineering,  
 Instrument Transformers.

Re: SPECIAL APPROVAL - One Only Ferranti-Packard Type "K35"  
 Outdoor Oil-Insulated Metering Equipment,  
 Serial Number 2-32731

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only type "K35" 50/100-5 amp., 27600-115 volt, 60-cycle, 3 phase - 3 wire Outdoor Oil-Insulated Metering Equipment, Serial Number 2-32731. This equipment contains:

- 2 - type "K35" Current Transformers, approved under Circular 3-EA./27 (amended); and
- 2 - type "K35" Voltage Transformers, 27600-115 volts, 60 cycles, Serial Numbers 2-32777 and 2-32778, having a name-plate accuracy rating of "0.3%".

This equipment is for The Hydro-Electric Power Commission of Ontario for installation at Welland, Ontario.

Yours very truly,

*K. Cryer*

K. Cryer, Chief,  
 Electricity and Gas Division,  
 Standards Branch.

RAW/moe

c.c. to Mr. C. D. Briggs, District Inspector of Electricity & Gas, Hamilton  
 c.c. to The Hydro-Electric Power Comm. of Ontario (through Mr. Briggs)