

SE-85-1-5
 SE-85-1-6
 SI-100-SPE
 SL-100-596 V₂P

Ottawa, July 6, 1955.

Ferranti-Packard Electric Limited,
 ST. CATHARINES,
 Ontario.

Attention: Mr. E. L. Hill,
 Supervisor of Engineering,
 Instrument Transformers.

Re: SPECIAL APPROVAL -- One Only Ferranti-Packard Type "EM45"
 Outdoor Oil-Insulated Metering Outfit,
 Serial Number 2-31621

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only type "EM45" 100/200-5 esp., 27000/16000-115 volt, 60-cycle, 3 phase - 3 wire Outdoor Oil-Insulated Metering Outfit, Serial Number 2-31621. This outfit contains:

- 2 - type "EC45" Current Transformers, approved under Circular 3-2A.427 (amended); and
- 2 - type "EM45" 16000-115/191.67 volts, 60 cycles Voltage Transformers with an extended secondary winding to give 115 secondary volts with either 16000 or 27000 primary volts. The nameplate marking in either case is "0.62".

This outfit is for The Hydro-Electric Power Commission of Ontario for installation at the Crown Cork and Seal Company Limited, Vaughan Acres Subdivision in Vaughan Township, Toronto, Ontario.

Yours very truly,

E. Cryer
 E. Cryer, Chief,
 Electricity and Gas Division,
 Standards Branch.

RAH/nee

C.C. to: Mr. E. H. Nelson, District Inspector of Electricity & Gas, Toronto
 C.C. to: The Hydro-Electric Power Commission of Ontario (through Mr. Nelson)