

SP-85-43
 SP-85-46
 SL-100-SPE
 SL-596 V50

Ottawa, July 6, 1965.

Ferranti-Packard Electric Limited,
 ST. CATHARINES,
 Ontario.

Attention: Mr. H. L. Mills,
 Supervisor of Engineering,
 Instrument Transformers

Re: SPECIAL APPROVAL - One Only Ferranti-Packard Type "K1069"
 Outdoor Oil-Filled Metering Equipment,
 Serial Number 2-77029

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only type "K1069" 100/200-5 amp., 69000-115 volt, 60-cycle, 3 phase - 3 wire Outdoor Oil-Filled Metering Equipment, Serial Number 2-77029. This equipment contains:

- 2 - type "K1069" 69000-115 volt, 60-cycle Voltage Transformers, Serial Numbers 2-77025 and 2-77026; and
- 2 - type "K1069" 100/200-5 amp. Current Transformers with the double ratio obtained by a series parallel primary.

The nameplate is marked "0.333" for the voltage transformers, and "0.330.9" for the current transformers.

This equipment is for the British Columbia Hydro and Power Authority, Vancouver, B.C.

Yours very truly,

K. Cryer
 K. Cryer, Chief,
 Electricity and Gas Division,
 Standards Branch.

EAV/moa

c.c. to: Mr. R. G. D. Ward, District Inspector of Elec. & Gas, Vancouver
 c.c. to: B. C. Hydro and Power Authority (through Mr. Ward)