

SE-85-1-5

SE-85-4-6

SI-100-SPE

SI-100-526 V₅R

Ottawa, July 6, 1965.

Ferranti-Packard Electric Limited,
ST. CATHARINES,
Ontario.

Attention: Mr. E. L. Mills,
Supervisor of Engineering,
Instrument Transformers.

Re: SPECIAL APPROVAL - One Only Ferranti-Packard Type "RC69"
Outdoor Oil-Insulated Metering Equipment,
Serial Number 2-32213

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only type "RC69" 150/300-5 amp., 69000-115 volt, 60-cycles, 3 phase - 3 wire Outdoor Oil-Insulated Metering Equipment, Serial Number 2-32213.


This equipment contains:

- 2 - type "RC69" 69000-115 volt Voltage Transformers, Serial Numbers 2-32214 and 2-32215; and
- 2 - type "RC69" 150/300-5 amp. Current Transformers, Serial Numbers 2-32216 and 2-32217.

The nameplate accuracies are "0.333%" for the voltage transformers, and "0.333.9" for both ratios of the current transformers.

This equipment is for The New Brunswick Electric Power Commission at Newcastle, New Brunswick.

Yours very truly,



R. Cryer, Chief,
Electricity and Gas Division,
Standards Branch.

RAU/ncs

c.c. to: Mr. R. E. Beattie, District Inspector of Elec. & Gas, Saint John
c.c. to: The New Brunswick Electric Power Commission (through Mr. Beattie)