

SP-35-46

SL-100-517

SL-100-517 T

Ottawa, July 6, 1965.

Ferranti-Packard Electric Limited,
 ST. CATHARINES,
 Ontario.

Attention: Mr. E. L. Mills,
 Supervisor of Engineering,
 Instrument Transformers.

Re: SPECIAL APPROVAL - One Only Ferranti-Packard Type "VU15"
 Voltage Transformer, Serial Number
 2-31697


Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only type "VU15" 7620/13200Y-120 volt, 60-cycle Outdoor Compound-Filled Voltage Transformer, Serial Number 2-31697.

The ratio of this transformer is 63.5-1 and the accuracy class marked on the nameplate is "0.3%".

This transformer is for Hydro-Quebec for installation at La Sarre, Abitibi Ouest, P.Q.

Yours very truly,



K. Tryer, Chief,
 Electricity and Gas Division,
 Standards Branch.

RAW/aes

c.c. to Mr. G. C. Piirainen, District Inspector of Elec. & Gas, Sudbury
 c.c. to Hydro-Quebec (through Mr. Piirainen)