

SE-85-4-6  
SL-100-712K  
SL-100-SPF

Ottawa, September 17, 1965.

Ferranti-Packard Electric Limited,  
ST. CATHARINES,  
Ontario.

Attention: Mr. E. L. Mills,  
Supervisor of Engineering,  
Instrument Transformers.

Re: SPECIAL APPROVAL - Seven Only Ferranti-Packard Type "MG-69"  
Outdoor Oil-Insulated Voltage Transformers,  
Serial Numbers 2-86194, -5, -6, -7, -8, -9  
and 2-86200


Dear Sirs:

This is to advise that Special Approval has been granted by  
the Standards Branch for use in Canada for billing purposes to seven only  
type "MG-69" 40250/69000Y - 67.08-115 volts, 60 cycles, Outdoor Oil-Insu-  
lated Voltage Transformers, Serial Numbers 2-86194, -5, -6, -7, -8, -9  
and 2-86200.

The accuracy of each secondary is 0.3WYZ, 0.6ZZ and the name-  
plate marking is "0.3Z".

These transformers are for the Newfoundland Light & Power  
Company, St. John's, Newfoundland.

Yours very truly,

  
K. Cryer, Chief,  
Electricity and Gas Division,  
Standards Branch.

EAW/mec

c.c. to: Mr. J. M. Taylor, Dist. Insp. of Electricity and Gas, St. John's  
c.c. to: Newfoundland Light & Power Company Limited (through Mr. Taylor)