

SE-85-4-6  
SL-100-712L  
SL-100-SPE

Ottawa, September 17, 1965.

Ferranti-Packard Electric Limited,  
ST. CATHARINES,  
Ontario.

Attention: Mr. E. L. Mills,  
Supervisor of Engineering,  
Instrument Transformers.

Re: SPECIAL APPROVAL - Three Only Ferranti-Packard Type "MK69"  
Outdoor Oil-Insulated Voltage Transformers,  
Serial Numbers 2-86630, -31, -32

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to three only type "MK69" 40250/69000Y-67.08-115 volts, 60 cycles, Outdoor Oil-Insulated Voltage Transformers, Serial Numbers 2-86630, -31, -32.

The accuracy of these transformers is 0.3% XYZ, 0.6% ZZ and the nameplate marking is "0.3%".

These transformers are for the Shawinigan Water and Power Company at Trois Rivières, P.Q.

Yours very truly,

K. Cryer, Chief,  
Electricity and Gas Division,  
Standards Branch.

RAV/mee

C.C. to: Mr. G. Readman, Dist. Insp. of Electricity and Gas, Trois Rivières  
S.C. to: Shawinigan Water and Power Company (through Mr. Readman)