

3F-15-4-6  
 SE-85-4-5  
 SL-100-596V50  
 SL-100-SPE

Ottawa, September 17, 1965.

Ferranti-Packard Electric Limited,  
 ST. CATHARINES,  
 Ontario.

Attention: Mr. E. L. Mills,  
 Supervisor of Engineering,  
 Instrument Transformers.

Re: SPECIAL APPROVAL - One Only Ferranti-Packard type "KC25" Outdoor  
 Oil-Insulated Metering Outfit, Serial Number  
 2-82335

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only type "KC25" 100/200-5 amp., 24000-120 volt, 60-cycle, 3-phase 3-wire, Outdoor Oil-Insulated Metering Equipment, Serial Number 2-82335. This equipment contains:-

- 2 - type "MC25" 24000-120 volt Voltage Transformers, Serial Numbers 2-23331 and 2-82332; and
- 2 - type "KC25" 100/200-5 amp. Current Transformers, as approved under Circular S-BA.427(amended).

The nameplate accuracies are "0.32%" for the voltage transformers, and "0.250.9" for both ratios of the current transformers.

This equipment is for the British Columbia Hydro & Power Authority at Nanaimo, B. C.

Yours very truly,

*K. Cryer*  
 K. Cryer, Chief,  
 Electricity and Gas Division,  
 Standards Branch.

EAW/mee

C.c. to: Mr. R. G. D. Ward, District Inspector of Elec. & Gas, Vancouver  
 C.c. to: British Columbia Hydro & Power Authority (through Mr. Ward)