

SE-85-46
 SP-85-45
 SL-100-596V5P
 SL-100-SPE

Ottawa, September 17, 1965.

Ferranti-Packard Electric Limited,
 ST. CATHARINES,
 Ontario.

Attention: Mr. E. L. Mills,
 Supervisor of Engineering,
 Instrument Transformers.

Re: SPECIAL APPROVAL -- One Only Ferranti-Packard Type "KM25"
 Metering Outfit, Serial Number 2-85780

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only type "KM25" 50/100-5 amp., 24000-120 volt, 60-cycle, single-phase Metering Outfit, Serial Number 2-85780. This outfit contains:-

- 1 - type "MC25" 24000-120 volt Voltage Transformer, Serial Number 2-85778; and
- 1 - type "KC25" 50/100-5 amp., Current Transformer, as approved under Circular S-EA.427(amended).

The nameplate accuracies are "0.3ZZ" for the voltage transformer, and "0.3B0,9" for both ratios of the current transformer.

This outfit is for the Manitoba Hydro at Fort Garry, Manitoba.

Yours very truly,

K. Cryer
 K. Cryer, Chief,
 Electricity and Gas Division,
 Standards Branch.

RAV/see

c.c. to: Mr. R. H. Young, Dist. Insp. of Electricity and Gas, Winnipeg
 c.c. to: Manitoba Hydro (through Mr. Young)