

SE-85-1-6
 SE-85-1-5
 6L-100-596V5Q
 SL-100-SPE

Ottawa, September 17, 1965

Ferranti-Packard Electric Limited,
 ST. CATHARINES,
 Ontario.

Attention: Mr. E. L. Mills,
 Supervisor of Engineering,
 Instrument Transformers

Re: SPECIAL APPROVAL - One Only Ferranti-Packard Type "KC46"
 Metering Equipment, Serial Number 2-84838

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only type "KC46" 50/100-5 amp., 48000-120 volts, 60-cycle, 3-phase 3-wire, Outdoor Oil-Insulated Metering Equipment, Serial Number 2-84838. This equipment contains:

- 2 - type "MV/6" 48000-120 volt, 60-cycle, oil-insulated Voltage Transformers, Serial Numbers 2-84834 and 2-84835; and
- 2 - type "KC46" 50/100-5 amp. Current Transformers, as approved under Circular S-EA.427 (suspended).

The nameplate accuracies are "0.32%" for the voltage transformers, and "0.300%" for both ratios of the current transformers.

This equipment is for the Southern Canada Power Company Limited, Meter Department, St. Hyacinthe, P. Q.

Yours very truly,

R. Cryer, Chief,
 Electricity and Gas Division,
 Standards Branch.

RAV/mee

c.c. to Mr. J. P. Neysmith, D.I. of Electricity and Gas, Montreal
 c.c. to Southern Canada Power Company Limited (through Mr. Neysmith)