

SE-85-4-5
 SZ-85-4-6
 SL-100-518V2U
 SL-100-SPE

Ottawa, December 9, 1965.

Ferranti-Packard Electric Limited,
 ST. CATHARINES,
 Ontario.

Attention: Mr. E. L. Mills,
 Supervisor of Engineering -
 Instrument Transformers.

Re: SPECIAL APPROVAL - One Only Ferranti-Packard Type "CS315"
 Metering Equipment, Serial Number 2-88119


Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only type "CS315" 200/400-5-5 amps., 7200/12470Y-120-120 volts, 60 cycles, 3-phase 4-wire Outdoor Oil-Insulated Metering Equipment, Serial Number 2-88119. This equipment contains:-

- 2 - type "MD15" 7200/12470Y-120-120 volt Voltage Transformers, Serial Numbers 2-85971 and 2-85972. Each transformer has double secondary windings, each producing 120 rated volts, and each having an accuracy classification of 0.3%/0.3%; and
- 3 - type "ES.7 Special" 200/400-5-5 amp. Current Transformers, Serial Numbers 2-88116, 2-88117 and 2-88118. Each transformer is made up of two separate units with each secondary centre-tapped to give ratios of 200-5 and 400-5 so that if only one of the pair is in use, the other must be short-circuited. The accuracy class is 0.380.9 on both ratios of each unit.

This equipment is for the British Columbia Hydro and Power Authority at Vancouver, B. C.

Yours very truly,


 K. Gryer, Chief,
 Electricity and Gas Division,
 Standards Branch.

BAW/mee

c.c. to: Mr. R. G. D. Ward, District Inspector of Electricity & Gas, Vancouver
 c.c. to: The British Columbia Hydro and Power Authority (through Mr. Ward)