

RECEIVED  
ELECTRICITY  
DEPARTMENT

OTTAWA, January 14, 1966

Canadian Electric Company Limited,  
Distribution Department,  
P.O. Box 2062,  
Ottawa,  
Ontario

Attention: Mr. F. W. Wilson, P. Eng.  
Engineering Department,  
"Saskatoon Division Station"

**RE: SPECIAL APPOINTMENT - Two Only Canadian Manufacturers  
Type 25-00 10/25-00 Amps, Full  
Load Current Symmetrical Short  
Circuit 15750 and 15700.**

Dear Sirs:

This is to advise that a special approval has been granted  
by the Standards Branch for use in Canada for utility purposes to  
two only Canadian manufacturers Type 25-00 10/25-00 Amps, full load  
current transformers serial numbers 15750 and 15700.

On the 25-00 ratio the accuracy is 0.1% at all currents from  
5% up to and including 100% and on the 10/25-00 ratio the accuracy is  
0.2%, 0.3%, 0.4%, 0.5% and 0.6% at currents of 10%, 20%, 30%, 40% and 50%.

These units are for, and may be supplied to, the Public  
Utilities Commission, Fort Worth, Ontario.

Yours very truly,

*K. C. Coyne*  
K. C. Coyne,  
Chief, Electricity and Gas Division,  
Standards Branch.

cc: to

cc: to Mr. J. P. Briggs, District Inspector of Electricity and Gas, Fort Hill  
cc: to Public Utilities Commission, Fort Worth (through Mr. Briggs)