

25-4-5
25-4-6
1-100-
21-100-78

Ottawa, May 2nd, 1966

Sherman-Dickard Electric Limited,
St. Catharines, Ontario.

Attention: Mr. W. L. Hills,
Supervisor of Engineering

Re: Special Approval: Two only Type "3835" 400/300-5 amp.,
27600-115 volts, 60 cycles 3 phase 3
wire Outdoor Oil Insulated Metering
Equipments serial numbers 2-89908-9.

Dear Sirs:

This is to advise that Special Approval has been granted by
the Standards Branch, for use in Canada for billing purposes to two only
Type "3835" 400/300-5 amp., 27600-115 volts, 60 cycles, 3 phase 3 wire
Outdoor Oil Insulated Metering Equipments serial numbers 2-89908-9.

These outfits contain 2 Type "3835" current transformers and
2 Type "3835" voltage transformers.

The average accuracy is 0.25% for the current transformers
and 0.25% for the voltage transformers.

These units are for the Hydro Electric Power Commission of
Ontario for installation at the H.E.P. Plant at Leithton, Ontario.

Yours truly,

J. Dryer,
Chief, Electrical Division,
Standards Branch.

C.C. Mr. W. L. Hills, P.E., of S. D. E. Toronto, Ontario,
Hydro Electric Power Commission (through Mr. ...)