

SF-35-1-6
SI-100-3
SI-100-SPE

Ottawa, May 27, 1966.

Canadian General Electric Company Limited,
940 Lansdowne Avenue,
Toronto 4,
Ontario.

Attention: Mr. R. D. Maguire,
Manager - Engineering & Laboratory,
Distribution & Specialty Transformers.

SPECIAL APPROVAL - Four Only General Electric Type "JVT-200"
25000-125 volt Voltage Transformers,
Serial Numbers G 414613-4-5-6.

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to four only type "JVT-200", 25000-125 volt, Voltage Transformers, Serial Numbers G 414613-4-5-6. Each transformer has a single secondary winding and the nameplate accuracy is 0.3WKYZ,ZZ.

These units are for use by Hydro-Quebec in the Expo 67 area.

Yours very truly,

W. Dryer,
Chief, Electricity and Gas Division,
Standards Branch.

c.c. to: Mr. J. E. Dumas, District Inspector of Electricity and Gas, Montreal
c.c. to: Hydro-Quebec (through Mr. Dumas)

EAW/mee