

SPX-0082

SPX-82

SE-35-6-7

SL-100-490 (G)

SL-100-SPE

Ottawa, June 1, 1966.

Sangamo Company Limited,
215 Laird Drive,
LEASIDE (Toronto 17),
Ontario.

Attention: Mr. M. R. Sabiston, P.Eng.,
Supervisory Engineer.

SPECIAL APPROVAL - One Only Sangamo Type "SC2" Graphic
Thermal Demand Meter with 20% raised
zero

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one only Sangamo type "SC2" Graphic Thermal Demand Meter with a 20% raised zero, Serial Number 6724202.

This recorder is a 4-element duplex graphic, 16-minute time of response, bottom-connected with a chart 0.2-0-0.8, 1/2" per hour. It will be used on a 3-phase 4-wire 8400/13800 volt system, calibrated for 300:5 ampere current transformers on the right-hand elements and 150:5 ampere current transformers on the left-hand elements.

It will be installed on the property of Atomic Energy Company, Sheridan Research Laboratories, Clarkson, Ontario.

Yours very truly,

K. Gryer,
Chief, Electricity and Gas Division,
Standards Branch.

EAW/mee


c.c. to: Mr. W. R. McEown, District Inspector of E&G, Toronto
c.c. to: Atomic Energy Company (through Mr. McEown)

C.G.E. Company Limited, Toronto 4
(Attention: Mr. W. E. Hooper)

July 13, 1961.

These oil-filled voltage transformers are for the Alcanair
Company of Canada Limited, for installation in Pittmeat, British Columbia.

Yours very truly,



R. J. W.,
Chief, Electricity and Gas Division,
Standards Branch.

KG/icc

c.c. to Mr. R. G. P. Ward, District Inspector of Electricity and Gas, Vancouver
c.c. to Alcanair Company of Canada Ltd. (through Mr. Ward)