

SE-85-2-6
SL-100-57 (H)
SL-100-3PE

Ottawa, July 20, 1966.

Canadian Westinghouse Company Limited,
P. O. Box 2220,
LONDON,
Ontario.

Attention: Mr. J. E. Highfield,
Engineering Assistant,
Engineering Department,
Distribution Apparatus Division.

SPECIAL APPROVAL - Two Only Type "RCT-9" 1000/500/250-5
Ampere Current Transformers, Serial
Numbers 521788 and 521789


Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to two only type "RCT-9" 1000/500/250-5 ampere Current Transformers, Serial Numbers 521788 and 521789.

These transformers are similar to those receiving approval under Circular S-BA, 520 except that the secondary has taps for the different ratios.

These units are for the Public Utilities Commission at Waterloo, Ontario, where the customer is "UNIVEX".

Yours very truly,



K. Cryer,
Chief, Electricity and Gas Division,
Standards Branch.

KAV/mec

c.c. to: Mr. C. D. Briggs, District Inspector of Electricity and Gas, Hamilton
c.c. to: Waterloo Public Utilities Commission (through Mr. Briggs)