

SPE-0085 Rev.1



Consumer and  
Corporate Affairs Canada

Consommation et  
Corporation Canada

Ottawa, Ontario  
K1A 0C9

Consumer Standards  
Directorate

Direction générale  
des normes

August 16, 1978

Your file    Votre référence

Our file    Notre référence

6565-F2-33

Ferranti-Packard Ltd.  
Dieppe Road  
St. Catherines, Ontario  
L2R 6W9

Attention: Mr. B. O'Connell  
Instrument Transformer Engineering

Re: Special Approval, KM69 Metering Outfit

Dear Mr. O'Connell:

Enclosed is our revised letter of Special Approval covering the subject metering outfit.

Please destroy the earlier notice.

Yours truly,

D. L. Smith  
Chief  
Electricity and Gas Division



Consumer and  
Corporate Affairs Canada

Consommation et  
Corporation Canada

SPE-85-1

Consumer Standards  
Directorate

Direction générale  
des normes

OTTAWA, July 11, 1978

Your file    Votre référence

Our file    Notre référence

G 6565-F2-33

SPECIAL APPROVAL

Granted to            Ferranti-Packard Limited  
                          Dieppe Road  
                          St. Catharines, Ontario  
                          L2R 6W9

Attention:            Mr. B. O'Connell, P.Eng.  
                          Instrument Transformer Engineering

Subject:              One only, Ferranti-Packard Type KC-69  
                          200 x 400/300/150 - 5A, 69000 Grd Y/40250  
                          115V, 60Hz Metering Outfit Serial No.  
                          2-96932

This is an amendment to SPE-85 to cover the replacement of the original current transformers for these of higher current rating, which are given the same accuracy rating. The serial numbers are: 2-451532, 2-451533 and 2-451534.

This metering outfit is in service at Deer Lake, Nfld. The contractor is Bowater Power Corporation.

D. L. Smith  
Chief  
Electricity and Gas Division  
Metrology Branch

c.c. Mr. J.W. Strachan, D.M., E & G St. John's  
Bowater Power Corporation (through Mr. Strachan) ✓