

SPE-0086

SPE-86

SE-35-2-6

SL-100-57(I)

SL-100-31E

Ottawa, September 6, 1966

Canadian Westinghouse Company Limited,
P. O. Box 2220,
LONDON,
Ontario.

Attention: Mr. J. E. Highfield,
Engineering Assistant,
Engineering Department,
Distribution Apparatus Division.

SPECIAL APPROVAL - Six Only Type "RGT-9" 2000/1000-5 ampere
Current Transformers, Serial Numbers
521341, -2, -3, -4, -5, -6.

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to six only type "RGT-9" 2000/1000-5 ampere current transformers, serial numbers 521341, -2, -3, -4, -5, -6.

These transformers are similar to those receiving approval under 3-74.520 except that the secondary has a tap, thus producing the dual ratio. The accuracy marked on the nameplate is "0.3 2.0" which applies to both ratios.

These units are for the Smaplot Chemical Company Limited,
Windsor, Manitoba.

Yours very truly,

K. Meyer, Chief,
Electricity and Gas Division,
Standards Branch.

MM/soe

C.C. to: Mr. W. M. Young, District Supervisor of Electricity and Gas, Winnipeg
C.C. to: Mr. J. E. Highfield, Engineering Assistant, Engineering Department, Distribution Apparatus Division, Canadian Westinghouse Company Limited, P. O. Box 2220, London, Ontario.
- through Mr. Young.