

SF-15-4-5
 SL-100-50(A)
 SI-100-SPE

Ottawa, October 11, 1966.

Ferranti-Packard Electric Limited,
 St. Catharines,
 Ontario.

Attention: Mr. E. L. Mills,
 Manager of Engineering,
 Instrument Transformers

SPECIAL APPROVAL - Three Only Ferranti-Packard Type "K133"
 100/300-5 Amps., 132000 Volts, 60 Cycle
 Outdoor Oil-Insulated Current Trans-
 formers, Serial Numbers 2-98114, 2-98115
 and 2-98116

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to three only type "K133" 100/300-5 amps., 132000 volts, 60 cycle outdoor oil-insulated current transformers, serial numbers 2-98114, 2-98115 and 2-98116.

The double ratio is obtained by means of a series/parallel primary; and the accuracy marked on the nameplate covering both ratios is "0.300.9".

These units are for the Calgary Power Company Ltd., for installation at Sarcee Sub-Station, Calgary, Alberta.

Yours very truly,

K. Cryer,
 Chief, Electricity and Gas Division,
 Standards Branch.

EAM/see

c.c. to: Mr. A. S. Park, Dist. Insp. of Electricity and Gas, Calgary
 c.c. to: Calgary Power Company Ltd. (through Mr. Park)