

SE-85-2-6  
 SL-100-309(R)  
 SL-100-SPE

Ottawa, November 16, 1966.

Canadian Westinghouse Company Limited,  
 P. O. Box 2220,  
 London,  
 Ontario.

Attention: Mr. T. W. Kolator, F.Eng.,  
 Engineering Department,  
Distribution Apparatus Division.

SPECIAL APPROVAL - Four Only Canadian Westinghouse  
 Type "OCT-46" 150/75-5 Amp. Outdoor  
 Current Transformers, Serial Numbers  
 285417, 285418, 285419 and 285420.

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to four only type "OCT-46" 150/75-5 Amp., Outdoor Current Transformers, Serial Numbers 285417, 285418, 285419 and 285420.

The accuracy on both ratios is 0.300.1, 80.2, 80.5 and the nameplates are marked "0.300.5".

These transformers are the property of The Pembroke Electric Light Company, Ltd. and will be located at the No.1 and No.4 substations of that Company.

Yours very truly,

K. Cryer,  
 Chief, Electricity and Gas Division,  
 Standards Branch.

FAW/mee

c.c. to: Mr. W. F. Miller, Dist. Insp. of Electricity and Gas, Ottawa  
 c.c. to: The Pembroke Electric Light Company, Ltd. (through Mr. Miller)