

SE-25-1-5
SL-100-983(a)
SL-100-SPE

Ottawa, December 2, 1965.

Ferranti-Packard Electric Limited,
ST. CATHARINES,
Ontario.

Attention: Mr. E. L. Mills,
Manager of Engineering,
Instrument Transformers.

SPECIAL APPROVAL - Three Only Ferranti-Packard Type "RR"
2000/1200-5 Amp., 60-Cycle, Bushing-type Current Transformers, Serial Numbers 2-203337, 2-203338 and 2-203339.

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to three only Ferranti-Packard type "RR" 2000/1200-5 amp., 60-cycle, bushing-type Current Transformers, serial numbers 2-203337, 2-203338 and 2-203339.

The double ratio is obtained by means of a tapped secondary winding. The 2000-5 ratio is obtained by using the secondary leads marked X1 and X3; and the 1200-5 ratio is obtained by using the leads marked X1 and X2. The accuracy class on the 2000-5 ratio is 0.3 on all burdens; and on the 1200-5 ratio it is 0.3 on all burdens except B2.0 which is 0.6. The accuracy rating marked on the nameplate is "0.300.9".

These transformers are for the Milton Public Utilities Commission at Milton, Ontario.

Yours very truly,

K. Cryer, Chief,
Electricity and Gas Division,
Standards Branch.

SAW/mes

c.c. to Mr. S. P. Briggs, Dist. Inst. of Electricity and Gas, Hamilton
c.c. to The Milton Public Utilities Commission (through Mr. Briggs)