

SE-85-9

SL-100-974 (P)

SL-100-SPE

Ottawa, December 13, 1966.

I-T-E Circuit Breaker (Canada) Limited,
(Eastern Power Devices Division).
2401 Dixie Road,
PORT CREDIT,
Ontario.

Attention: Mr. D. W. Gardner,
Transformer Engineer

SPECIAL APPROVAL - One Only Type "MCL5M1"
3000/2000/1500-5 Amp., Tapped
Secondary, 15KV Insulated Class
Current Transformer, Serial
Number 109294

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

The accuracy class marked on the nameplate is "0.300.5" at 60 cycles, which applies to all ratios.

This transformer is for The Hydro-Electric Power Commission of Ontario, for installation at Kirkland Lake, Ontario.

Yours very truly,

K. Cryer, Chief,
Electricity and Gas Division,
Standards Branch.

RAW/nce

c.c. to Mr. G. O. Piirainen, Dist. Insp. of ECG, Sudbury
c.c. to The Hydro-Electric Power Commission of Ontario (through Mr. Piirainen)