

SPE-0097 315-27

SL-85-0  
SL-100-974 (\*)  
SL-100-973

Ottawa, February 10, 1967.

I-T-E Circuit Breaker (Canada) Limited,  
(Eastern Power Devices Division),  
2401 Dixie Road,  
PORT CREDIT,  
Ontario.

Attention: Mr. E. V. Gardner,  
Transformer Engineer.

SPECIAL APPROVAL - Six Only - I-T-E Circuit Breaker  
Type "M15A1W" 3000-5 amp. Current  
Transformers, Serial Numbers 122975,  
122976, 122977, 122978, 122979 and  
122980

Dear Sirs:

This is to advise that Special Approval has been granted  
by the Standards Branch for use in Canada for billing purposes to the  
above-named apparatus.

The 60-cycle accuracy rating marked on the nameplate of  
each unit is 0.3% 0.5%.

These six current transformers are for use by the Toronto  
Hydro-Electric System in Toronto.

Yours very truly,

(for) K. Cryer, Chief,  
Electricity and Gas Division,  
Standards Branch.

RAM/rao

c.c. to: Mr. W. R. McLean, District Inspector of Electricity and Gas, Toronto  
c.c. to: Toronto Hydro Electric System (through Mr. McLean)