

SE-85-6-3  
SL-100-843 (C)  
SL-100-SPE

Ottawa, February 21, 1967.

The Hydro-Electric Commission of East York,  
175 Memorial Park Avenue,  
TORONTO 6,  
Ontario.

Attention: Mr. J. S. Shand, P.Eng.,  
Manager.

SPECIAL APPROVAL - Sangamo Type "WH21 Time Switch

Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to one Sangamo type "WH21" Time Switch for the purpose of disconnecting the potential supply to Sangamo "VA3" and "WD3" demand meters during the periods from 11:00 p.m. to 7:30 a.m. Monday to Thursday inclusive and from 11:00 p.m. Friday to 7:30 a.m. Monday.

The approval covers this time switch operating the specified demand meters in the specific manner as outlined by The Hydro-Electric Commission of East York and set forth in their letter of February 3, 1967 and accompanying circuit diagram.

The Metering Installation is identified as No. 112 and is located at Shoppers' World.

Yours very truly,

K. Gayer, Chief,  
Electricity and Gas Division,  
Standards Branch.

EAW/mee

c.c. to Mr. W. R. McEown, Dist. Insp. of Electricity and Gas, Toronto