

SE-85
SL-100-75(J)
SL-100-SIF

Ottawa, March 16, 1967.

Canadian Allis-Chalmers Limit. d.
P. O. Box 37,
MONTREAL,
Quebec.

Attention: Mr. H. Schmah,
Electrical Department.

SPECIAL APPROVAL - For Only Canadian Allis-Chalmers
Type "GEMT" 1500/750-5 Amp., 60 Hz.
Current Transformers, Serial Numbers
829-1 and 829-2


Dear Sirs:

This is to advise that Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

The accuracy rating of these transformers is 0.3B0.1, B0.2, B0.5, B0.9, B(2x0.9), B1.0, B2.0 on the 1500-5 ratio, and 0.3B0.1, B0.2, B0.5, B0.9, B(2x0.9) B1.0; 0.6B2.0 on the 750-5 ratio, and the nameplates are marked 0.3(Bx0.9).

These transformers are for use by the Nova Scotia Power Commission, P. O. Box 910, Halifax, Nova Scotia.

Yours very truly,


E. Cryer, Chief,
Electricity and Gas Division,
Standards Branch.

EAM/mos

c.c. to: Mr. P. C. Bruce, Dist. Insp. of Electricity and Gas, Halifax
c.c. to: The Nova Scotia Power Commission (through Mr. Bruce)