

175-21
U-100-76(V)
U-100-77

Ottawa, April 13, 1967.

Canadian Allis-Balzers Limited,
P. O. Box 37,
MONTREAL,
P. Q.

Attention: Mr. R. W. Brown,
Electrical Department.

RECIPIENT INFORMATION - Two (2) Canadian Allis-Balzers
Type "SBB" 2000/1000-5 Amp., 60 Hz.
Current Transformers, Serial Nos.
0772-01 and 0772-02

Dear Sirs:

This is to advise that special approval has been
granted by the Standards Branch Service in Canada for the
accuracy of the above-mentioned transformers.

The accuracy rating marked on the nameplate is
0.5%, 0.2%, 0.1% and applies to both ratios.

These transformers are for Allis-Balzers, Central
Station, Three Rivers, Quebec.

Yours very truly,

(S) J. J. ...
Electricity and Gas Division,
Standards Branch.

BAW/ma

c.c. to: Mr. S. ... District Inspector ... and Gen. Three Rivers
c.c. to: Hydro-Quebec (through ...)